



PLEASE PRINT

Owner's Name: SIDNEY JONES Address: RR# RICHARD SK. Drilling Contractor: DISCHMIDT DRLG. Registration Number: 093

Description of Well: Hole Number 1 Date Completed: Day 2 Month MAY Year 11 Completion Method:  1. Well Screen

Location of Well in Quarter: 145 Feet From  N Boundary  S Boundary  E Boundary  W Boundary

800 Feet From

Method Installed:  1. Drilled

Test Hole Depth (feet): 150 Bit Diameter (inches): 5 3/8 Water Level Before Pumping (feet):      If Flowing Artesian, Head Above Ground (feet):     

Depth Water Struck (feet):     

Legal Description of Quarter: Quarter Section NW 9 Township 44 Range 133 West of Mer     

Purpose of Water Use:  1. Domestic

Length (feet)	Bottom Set At (feet)	Diameter (inches)	Code	Material Description

Material Description	Material Code	Slot Size (1/1000 inch)	Diameter (inches)	Length (feet)	Bottom Set At (feet)


Method of Coupling:  Threaded.  Telescoped. Other     

Pump Test: Draw Down (feet)   Duration of Test (hours)   Pumping Rate (IGPM)  

Recommended: Pumping Rate (IGPM)   Pump Intake Set At (feet)   Water Temperature (°F)  

Electric:  1. Yes  2. No Log  2. No

Description of Material Encountered	Depth To (feet)	Primary	Colour	Description
TILL, BROWN & CREAM <u>bedrock 1</u>	-3			
TILL, GREY, OXIDIZED <u>COBBLES</u>	-35			
TILL, YELLOW	-40			
TILL, GREY, OXIDIZED <u>HARD</u>	-50			
CLAY, GREY, OXIDIZED	-55			
TILL, GREY, OXIDIZED <u>COBBLES SAND LAYERS 70-71</u>	-81			
SAND, YELLOW, FINE TO MED <u>TILL LAYER -86</u>	-85			
SAND, YELLOW, FINE TO COARSE	-91			
TILL, LAYER & SAND LAYER	-92			
TILL, GREY, BLUE TO PURP <u>HARD</u>	-105			
SAND, YELLOW, FINE, SILTY	-109			
SAND, YELLOW, MED TO COARSE <u>TILL LAYER 118</u>	-120			
SAND, YELLOW, MED TO COARSE & GRAVEL	-129			
TILL & SAND LAYER <u>COBBLES</u>	-132			
SAND, YELLOW, FINE TO COARSE <u>COBBLES 139</u>	-139			
TILL, GREY, HARD	-150			



0

